Facility Site Operations and Infrastructure Seismic / Substation #7 / Duct / Fans Round Sheet

Date: 03/7/14-032314

Location: BLDG. 413A, AREA SUB #7, & 41-B-700 A & B & C				DAY	SUN	MON		TUES		WED		THURS		FRI		SAT		SUN	
				SHIFT	2	1	2	1	2	1	2	1	2	1	2	1	2	1	2
				REVIEWER		Original Signatures on File													
				FOT															
				C/O															
ITEM	MIN	NORM	MAX																
(413A) SEISMIC PANEL 413A-SMP-004-001																			
413A-SMP-004-001 / POWER ON		ON [B]			(1)		3/6/14 ✓												
AREA SUBSTATION #7 AND TRANSFORMER																			
NO ABNORMAL CONDITIONS [A]		SAT [B]			✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	—	✓
XFMR LIQUID LEVEL	LOW	SAT [B]	HIGH		(2)	55 ✓ 03/7/14													
XFMR PRESS (kPa)	-2.5		7.5			0													
XFMR WINDING HIGH TEMP (`C)	RESET MONDAY		105`			52													
XFMR LIQUID HIGH TEMP (`C)	RESET MONDAY		105`			55													
UVFS DUCTWORK (NEAR BYPASS DAMPERS)																			
UVFS CONDENSATE CONTAINER LEVEL		[B] [C]	80%		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	—	✓
UVFS VENTILATION FAN OIL LEVELS																			
700A BRG OIL LEVELS	LOW	[B]	HIGH		✓	✓		✓		✓		✓		✓		✓		✓	
700B BRG OIL LEVELS	LOW	[B]	HIGH		✓	✓		✓		✓		✓		✓		✓		✓	
700C BRG OIL LEVELS	LOW	[B]	HIGH		✓	✓		✓		✓		✓		✓		✓		✓	

NOTES: [A] - THE PRESENCE OF LEAKS, UNUSUAL ODORS, OR NOISES CONSTITUTES AN ABNORMAL CONDITION.

[B] - IF NORMAL CONDITION EXISTS, ENTER A CHECK MARK; OTHERWISE NOTE EXISTING CONDITION.

[C] - WHEN CONTAINER IS 80% FULL, SUBMIT REQUEST FOR DISPOSAL (RFD)

COMMENTS: (1) No Access seismic reading taken from CMR. (cleared RSA)

(2) No Access (cleared RSA)

INFORMATION ONLY

APPROVED FOR USE/DATE: Original Signature on File

Facility Site Operations and Infrastructure Ventilation Fans Round Sheet

DATE: 03/7/14 - 03/23/14

Location: 413, EXHAUST FILTER BLDG. UVFS FANS	DAY	SUN	MON		TUES		WED		THURS		FRI		SAT		SUN	
	SHIFT	2	1	2	1	2	1	2	1	2	1	2	1	2	1	2
	REVIEWER		Original Signatures on File													
	FOT	C/O														

ITEM	MIN	NORM	MAX														
413-CP-056-01																	
CONTROL PANEL 860 FANS [A]		SAT [B]		(1)		(1)		(1)		(1)		(1)		(1)		(1)	
413-CP-307-01B																	
CONTROL PANEL 700 FANS [A]		SAT [B]		(2)		(2)		(2)		(2)		(2)		(2)		(2)	
413-CP-056-01C																	
860A U/G FILTRATION FAN (KSCFM)	[D]	[C] [D]	[D]	59 (3)	58 (3)	59 (3)	59 (3)	59 (3)	59 (3)	59 (3)	59 (3)	59 (3)	59 (3)	59 (3)	59 (3)	58 (3)	58 (3)	58 (3)
413-CP-056-01D																	
860B U/G FILTRATION FAN (KSCFM)	[D]	[C] [D]	[D]	SEC	SEC	SEC	SEC	SEC	SEC	SEC	SEC	SEC	SEC	SEC	SEC	SEC	SEC	SEC
413-CP-056-01E																	
860C U/G FILTRATION FAN (KSCFM)	[D]	[C] [D]	[D]	SEC	SEC	SEC	SEC	SEC	SEC	SEC	SEC	SEC	SEC	SEC	SEC	SEC	SEC	SEC
413-CP-307-01J																	
700A U/G VENTILATION FAN (KSCFM)	[D]	[D]	[D]	TAG (4)	TAG (4)	TAG (4)	TAG (4)	TAG (4)	TAG (4)	TAG (4)	TAG (4)	TAG (4)	TAG (4)	TAG (4)	TAG (4)	TAG (4)	TAG (4)	TAG (4)
413-CP-307-01K																	
700B U/G VENTILATION FAN (KSCFM)	[D]	[D]	[D]	TAG (5)	TAG (5)	TAG (5)	TAG (5)	TAG (5)	TAG (5)	TAG (5)	TAG (5)	TAG (5)	TAG (5)	TAG (5)	TAG (5)	TAG (5)	TAG (5)	TAG (5)
413-CP-307-01H																	
700C U/G VENTILATION FAN (KSCFM)	[D]	[D]	[D]	TAG (6)	TAG (6)	TAG (6)	TAG (6)	TAG (6)	TAG (6)	TAG (6)	TAG (6)	TAG (6)	TAG (6)	TAG (6)	TAG (6)	TAG (6)	TAG (6)	TAG (6)

INFORMATION ONLY

NOTES: [A] - CHECK THAT THE AUDIBLE ALARM SOUNDS AND THE ALARM LIGHTS ILLUMINATE. [B] - IF NORMAL CONDITIONS EXIST, ENTER A CHECK MARK; OTHERWISE NOTE EXISTING CONDITION. [C] - FLOW READINGS TAKEN AT STA. B), (NOTE: EFB HVAC FLOW INCLUDED IN STA. B READING). [D] - VENTILATION MODES (chart below)

NORMAL MODE (flow per fan l/S) -	MIN = 202	NORM = 212	MAX = 223	MBP MODE w/ 1-860/1-700 FANS (combined flow of all fans l/S) -	MIN = 200	MAX = 275
ALTERNATE MODE (flow per fan l/S) -	MIN = 247	NORM = 260	MAX = 273	MBP MODE w/ 1-860/2-700 FANS (combined flow of all fans l/S) -	MIN = 395	MAX = 425
MINIMUM MODE (flow per fan l/S) -	MIN = 57	NORM = 60	MAX = 63	MBP MODE w/ 2-860/1-700 FANS (combined flow of all fans l/S) -	MIN = 200	MAX = 275
REDUCED MODE (flow per fan l/S) -	MIN = 57	NORM = 60	MAX = 63	MBP MODE w/ 2-860/2-700 FANS (combined flow of all fans l/S) -	MIN = 395	MAX = 425
FILTRATION MODE (flow per fan l/S) -	MIN = 57	NORM = 60	MAX = 63			

COMMENTS: (1) Alarm 005 AR # 1307583 (3) Reading Taken in error (5) Out of Spec AR# 113255 (6) Out of Spec AR# 113256

(2) Alarm 005 AR# 1307584 (4) Out of Spec AR# 113257

APPROVED FOR USE/DATE: Original Signature on File

Facility Site Operations and Infrastructure Bldg 458 / 456 Round Sheet

Date: 03/14-03/23/14

Location:	DAY	SUN	MON		TUES		WED		THURS		FRI		SAT		SUN	
458, GUARD & SECURITY BUILDING	SHIFT	2	1	2	1	2	1	2	1	2	1	2	1	2	1	2
456, PUMPHOUSE BUILDING	REVIEWER															
	FOT	C/O														

Original Signatures on File

ITEM	MIN	NORM	MAX														
458, GUARD & SECURITY BUILDING																	
412 ODOR ABS MOD FILTER (PDI-07)			0.5	STBY	STBY												
412 ODOR ABS CHAR FILTER (PDI-08)			0.5														
412 ODOR ABS MOD FILTER (PDI-09)			0.5														
403 AHU LOW FILTER (PDI-03)			0.5														
403 AHU MOD FILTER (PDI-04)			0.5														
456-CP-010-01 CONTROL PANEL																	
DOMESTIC WATER PRESS (PIC-01)	60	65	70	66	65	66	65	65	62	64	65	65	65	65	65	65	65
456-FIY-010-001 WATER FLOW METER																	
RAW WATER GALLONS		RESET MONDAY [A]		84337		38860											
DOMESTIC WATER GALLONS		RESET MONDAY [A]		5847		52804											
456-FM-045-001 SEWAGE FLOW METER																	
SEWAGE FLOW GALLONS		[B]	23,000	282200		325400		379200		443000		959700		518200		529000	529,200
HACH TEST KIT																	
COLORIMETER FREE CL2 (PPM)	0.7	[C]	1.2	1		.99		.95		.94		1.03		.99		.99	.85

INFORMATION ONLY

NOTES: [A] - RESET METER AFTER TAKING THE READING ON MONDAY SECOND SHIFT

[B] - REQUIRED FOR COMPLIANCE WITH NMED DISCHARGE PERMIT DP-831 -- IF MAX LIMIT OF 23,000 GPD IS EXCEEDED CONTACT FSM

[C] - ADJUST CHLORINE LEVELS BY EITHER ADDING WATER (CHLORINE ABOVE 1.2) OR ADDING CHLORINE (CHLORINE BELOW .7) TO MAINTAIN SPECIFICATIONS

COMMENTS: ① Out of Cal Ark # 1402156

② FSM notified

APPROVED FOR USE/DATE: Original Signature on File

Facility Site Operations and Infrastructure Domestic / Fire Water Round Sheet

RCRA /TSR

Date: 03/7/14-032314

Location:	DAY	SUN	MON		TUES		WED		THURS		FRI		SAT		SUN	
	SHIFT	2	1	2	1	2	1	2	1	2	1	2	1	2	1	2
456, PUMPHOUSE BUILDING	REVIEWER		Original Signatures on File													
	FOT	C/O														

ITEM	MIN	NORM	MAX																
DOMESTIC WATER STORAGE TANKS																			
01A SOUTH WATER STG TNK LVL LI-01 (456-LT-006-001) [SR 4.1.1.9]	80%	[D]		98	97	100	100	100	100	100	100	100	100	100	100	100	100	100	100
01A VISUAL INSPECTION [A]		SAT[B][C]		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
01B NORTH WATER STG TNK LVL LI-02 (456-LT-006-002)	60%			94	93	92	90	90	88	88	86	85	83	84	84	84	84	84	84
01B VISUAL INSPECTION [A]		SAT[B][C]		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
TIME OF INSPECTION					0815	2130	0838	2000	0830	2000	0910	2052	0914	2056	1001	2200	1000	2125	

NOTES: [A] - IF NORMAL CONDITIONS EXIST, AND THE INSPECTION IS SATISFACTORY, ENTER A CHECK MARK; OTHERWISE NOTE EXISTING CONDITION.
[B] - INSPECT FOR LEAKS, VISIBLE CORROSION, INSULATION INTACT, ETC.
[C] - WHEN A NOTED CONDITION IS CORRECTED, ENTER THE DATE AND NATURE OF REPAIRS; OR OTHER REMEDIAL ACTION TAKEN THAT CORRECTED THE CONDITION.
[D] - LCO REQUIREMENT: LEVEL IN FIRE WATER TANK MUST BE ≥ 105,000 GALLONS (65%). IF NOT IMMEDIATELY NOTIFY FSM. COMPLETE THE SURVEILLANCE DATA SHEET FOR LCO 3.1.1, SURVEILLANCE REQUIREMENT 4.1.1.9, FORWARD THE COMPLETED SURVEILLANCE DATA SHEET TO THE FSM.

COMMENTS: (STATE AR NUMBER SUBMITTED TO CORRECT ABNORMAL CONDITION IF/WHEN KNOWN)

APPROVED FOR USE/DATE: Original Signature on File

OPERATORS INITIALING THIS LOGSHEET SHALL COMPLETE THE FOLLOWING:

NAME (PRINT)	INITIALS	NAME (PRINT)	INITIALS	NAME (PRINT)	INITIALS

Original Signatures on File

INFORMATION ON

Facility Site Operations and Infrastructure Support Bldg Substation / UPS Round Sheet **RCRA** Date: 031714-032314

Location: 451, ELEC. EQUIP. RM. 116 CMR		DAY	SUN	MON		TUES		WED		THURS		FRI		SAT		SUN	
		SHIFT	2	1	2	1	2	1	2	1	2	1	2	1	2	1	2
		REVIEWER		Original Signatures on File													
		FOT	C/O														
ITEM	**MIN**	**NORM**	**MAX**														
45P-SWG04/1 SUPPORT BUILDING SUBSTATION																	
NO ABNORMAL CONDITIONS [A]		SAT [B]		✓	✓	—	✓	—	—	✓	✓	✓	✓	—	✓	—	✓
TR-15/1 XFMR HIGH TEMP (°C)	RESET	MONDAY	170°	60	60												
45P-UPS03/2 SUPPORT BUILDING UPS																	
NORMAL OPERATION LOAD ON UPS		[B]		✓	✓	—	✓	—	—	✓	✓	✓	✓	—	✓	—	✓
AIR CONDITIONER NORMAL OPERATION		[B] [C]		✓	✓	—	✓	—	—	✓	✓	—	✓	—	✓	—	✓ (1)
ALTERNATE SOURCE AVAILABLE		[D]		✓	✓	—	✓	—	—	✓	✓	✓	✓	—	✓	—	✓
TIME OF INSPECTION				0801	1900	0712	~~0715~~ 0715	0730	~~0715~~ 0715	0756	0759	0731	2003	0829	2130	0700	2100
EMERGENCY PHONE CHECK		[E]		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓

NOTES: [A] - THE PRESENCE OF LEAKS, UNUSUAL ODORS, OR NOISES CONSTITUTES AN ABNORMAL CONDITION.

[B] - IF NORMAL CONDITIONS EXIST, ENTER A CHECK MARK; OTHERWISE NOTE EXISTING CONDITION.

[C] - LOW HUMIDITY ALARM IS NOT AN ABNORMAL CONDITION.

[D] - 45P-MCC04/3 CB-23 IS CLOSED

[E] - VERIFY EMERGENCY PHONE LINE HAS A DIAL TONE. IF NOT, CONTACT THE FSM.

INFORMATION ONLY

COMMENTS: (1) Air Conditioner doesn't work (AR # 1402949)

APPROVED FOR USE/DATE: Original Signature on File

Facility Site Operations and Infrastructure RH Room D/P and HVAC Panel Round Sheet

Date: 03/14-032314

Location:				DAY	SUN	MON		TUES		WED		THURS		FRI		SAT		SUN	
COMPUTER STATIONS				SHIFT	2	1	2	1	2	1	2	1	2	1	2	1	2	1	2
CMR, FSM DESK, LOCAL				REVIEWER		Original Signatures on File													
411, WHB MECH EQUIP RM 200 & 208				FOT	C/O														
ITEM			MIN	NORM	MAX														
RH ROOM DPs																			
OPERATING GALLERY	PDD-01	"wc				SEC	SEC		SEC		SEC		SEC		SEV		SEC		SEC
MANIP. REPAIR RM.	PDD-21A	"wc																	
FILTER GALLERY	PDD-21B	"wc																	
CASK LOADING RM.	PDD-21C	"wc																	
CASK TRANSFER CELL	PDD-21D	"wc																	
WASTE HOIST OPER RM	PDD-21G	"wc																	
SERVICE ROOM	PDD-21H	"wc	-0.00		-0.15														
RH BAY	PDD-21F	"wc	0.02		0.7														
HOT CELL	PDT-52	"wc	-0.04		-1.1														
HVAC CONTROL PANEL CHECKS																			
411-CP-051-10	(803/805 AHU/EXH FANS)			SAT [A]		✓	✓		✓		✓		✓		✓		✓		✓
411-CP-051-11	(804/806 AHU/EXH FANS)			SAT [A]		✓	✓		✓		✓		✓		✓		✓		✓
411-CP-051-12	(878 A/B EXH FANS)			SAT [A]		✓	✓		✓		✓		✓		✓		✓		✓
411-CP-058-17	(807 AHU FAN)			SAT [A]		✓	✓		✓		✓		✓		✓		✓		✓

NOTES: [A] - IF NORMAL CONDITIONS EXIST, ENTER A CHECK MARK; OTHERWISE NOTE EXISTING CONDITION.

COMMENTS:

APPROVED FOR USE/DATE: Original Signature on File

INFORMATION ONLY

Facility Site Operations and Infrastructure WHB CH Room D/P / HVAC / Air Dryer Round Sheet

Date: 03/7/14-032314

Location:			DAY	SUN	MON		TUES		WED		THURS		FRI		SAT		SUN	
COMPUTER STATIONS			SHIFT	2	1	2	1	2	1	2	1	2	1	2	1	2	1	2
CMR, FSM DESK, LOCAL			REVIEWER		Original Signatures on File													
411, WHB MECH EQUIP RM 200 & 208			FOT	C/O														
ITEM	MIN	NORM	MAX															
WHB CH ROOM DPs																		
SHIELDED STORAGE RM PDD-026A "wc				-.14	-.10		-.11		-.10		-.10		-.11		-.11		-.10	
CH AREA ROOM 103 PDD-026B "wc	-0.02			-.12	-.10		-.11		-.11		-.10		-.10		-.09		-.10	
SITE GEN WASTE RM. PDD-026C "wc				-.04	-.04		-.03		-.05		-.03		-.04		-.02		-.04	
EQUIP DECON RM. PDD-026D "wc				-.1	-.03		-.08		-.09		-.09		-.10		-.08		-.09	
OVERPACK & REPAIR RM PDD-026E "wc	-0.04			-.11	-.09		-.10		-.11		-.11		-.11		-.1		-.11	
CAGE LOADING ROOM PDD-006 "wc				.04	.06		.13		.07		.09		.08		.08		.08	
AIRLOCK ROOM 107 PDD-007 "wc				-.07	-.08		-.08		-.08		-.08		-.07		-.07		-.07	
HVAC CONTROL PANEL CHECKS																		
411-CP-052-15 (835/836 EXH FANS)		SAT [A]		✓	✓		✓		✓		✓		✓		✓		✓	
411-CP-063-16 (861/863 AHUS)		SAT [A]		✓	✓		✓		✓		✓		✓		✓		✓	
411-CP-052-14 (813/817 CH TRAIN)		SAT [A]		✓	✓		✓		✓		✓		✓		✓		✓	
411-CP-052-13 (812/816 CH TRAIN)		SAT [A]		✓	✓		✓		✓		✓		✓		✓		✓	
WASTE HANDLING BUILDING AIR DRYER																		
K-015 OUTLET (PSI)	95		135	115	116	116	115	114	116	114	115	115	116	117	116	115	115	115
K-015 AQUADEX INDICATOR		BLUE [A]		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
K-015 AUTO BLOWDOWNS /TEST		SAT [A]		✓		✓		✓				✓		✓		✓		✓
K-015 DRYER MODE		AMLOC [A]		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓

NOTES: [A] - IF NORMAL CONDITIONS EXIST, ENTER A CHECK MARK; OTHERWISE NOTE EXISTING CONDITION.

COMMENTS:

APPROVED FOR USE/DATE: Original Signature on File

INFORMATION ONLY